## **NuTone**

#### **DESCRIPTION**

- Efficient ventilation and bright light in one easy installation.
- Fan and light operate separately or together.
- Quiet operation with one-piece molded blower wheel and silent backdraft damper.
- · Attractive grille styling.
- Plug-in motor and light.
- Uses one (1) 100 watt incandescent bulb (bulb not included).
- Refer to NuTone's catalog for a complete listing of accessories to effectively adapt this Ventilation Fan with Light to your construction requirements.

#### **DESIGN FEATURES**

**Air Delivery:** 70 cfm. **Sound Level:** 4.0 Sones.

**Dimensions:** Housing:  $9" \times 9" \times 5\%$ .

Grille: 12" x 103/4".

**Lamp:** One 100W maximum A19

(bulb not included)

Material &

Component Data: Housing: Galvanized steel.

Grille: Engineered resin.

Lens: Translucent white polymeric.

**Reflector:** Aluminum. **Damper:** Polymeric.

**Motor:** Shaded pole, thermally protected.

**Electrical Rating:** With one (1) 100 watt bulb:

120 VAC, 60 Hz, 2.0 A

Blower Wheel: One-piece polymeric,

4¾" diameter.

**Duct Size:** 4" diameter.


**Mounting:** Mounting flange provided.





# Ventilation Fan with Light

**MODEL 769RL** 



#### **INSTALLATION**

- Suitable for use over tub or shower enclosure when installed in a GFCI protected branch circuit.
- · Installation instructions are included with each unit.
- Type IC for use with thermal insulation.
- Not for use with solid state speed controls.
- Not for use in kitchens.

#### ARCHITECT'S SPECIFICATIONS

Ventilation Fan with Light shall be NuTone Model 769RL as manufactured according to listed specifications. Fan shall ventilate 70 cfm at a sound level of 4.0 Sones. Housing shall be  $9^{\circ} \times 9^{\circ} \times 5^{3}$ 4 and connect to  $4^{\circ}$  duct.


Broan-NuTone LLC, 926 West State Street, Hartford, WI 53027 www.Broan-NuTone.com 1-800-558-1711

REFERENCE	QTY.	REMARKS	Project
			Location
			Architect
			Engineer
			Contractor
			Submitted by Date

02D 99044149C

#### MODEL 769RL CERTIFIED TEST DATA

#### AIR PERFORMANCE CURVE (4 In. Duct to 10 Foot Lengths)



### The air delivery of a ventilating system may be determined by:


- Determine the equivalent duct length for each 90 degree elbow by adding one foot of duct length for each inch of duct diameter, (i.e., a 4-inch diameter duct elbow equals 4 feet equivalent duct length).
- 2. Add the total straight length of duct and the equivalent length for each elbow to obtain the total equivalent duct length.
- Locate the intersection of the fan performance curve and the total equivalent duct length curves and draw a vertical line down to the (cfm) scale and read the system air performance.



HVI-2100 CERTIFIED RATINGS comply with new testing technologies and procedures prescribed by the Home Ventilating Institute, for off-the-shelf products, as they are available to consumers. Product performance is rated at 0.1 in. static pressure, based on tests conducted in a state-of-the-art test laboratory. Sones are a measure of humanly-perceived loudness, based on laboratory measurements.



#### MODEL 769RL DIMENSIONS





Product specification subject to change without notice.